



10/11/2022

Addendum 1

2022-23 Kanawha City Community Center Interior & Exterior Security Camera Project

This addendum is being issued to publish the technical questions and answers received, a pre-bid sign in sheet, and facility drawings.

1. Can you please provide a map of where you would like the cameras and recorder to be installed?

A) Map has been provided, but I would like for the vendor to choose the appropriate placement for the cameras to be installed. For the inside, I would like to make sure that we capture all entrance and exit doors, hallways, gym, weight room, game room, and lobby. For the outside I would like to capture the front entrance, front street, pool, tennis courts, tennis court walk way by the outside restrooms, basketball court, batting cage, and back of facility.

2. Does this job have to be Pelco since it was specified or will any equivalent system work?

A) No, any equivalent will work

3. Does this system need to be NDAA Compliant?

(<https://ipvm.com/reports/ndaa-guide> - provided as information on NDAA compliance)

A) Yes

4. What size monitor (TV) is required for viewing and where would it be installed?

A) No monitor is needed

5. During the walk thru it was discussed that 21 Cameras may not be enough, What is the number of Cameras that you are wanting installed?

A) No less than 21 cameras but can be more if needed. 360 cameras are not necessary if coverage can be captured with additional cameras.

6. How many people will require remote monitoring thru an app and/or via computer?

A) 3

7. To conserve on expense can the 360 camera be replaced with multiple fixed cameras?

A) Yes

8. How many days of recording storage do you want?

A) At least 60 days

9. Will 120v outlets be provided for Network Video Recorder and Network Switch?


A) Yes

10. Is a network rack going to be provided or is it needed in the bid?

A) Network rack is needed

11. Will a port be provided with internet access for remote viewing?

A) Yes



Kanawha County Rec Center

3511 Venable Ave

Google Earth

City of Charleston
2022-23 Kanawha City Community Center Interior & Exterior Security Camera Project
Pre-Bid Meeting Attendees

COMPANY NAME	CONTACT	ADDRESS	PHONE	EMAIL
S2F Construction	Christian Freeze	205 Clark Dr. St. Albans, WV	304-928-9988	cfreeze01@gmail.com Yahoo
Johnson Electric	James Johnson	P.O. Box 246 Coal R. Dse, WV 25825	304-228-3816	johnsonelectric2@gmail.com
Cerberus Security	Christopher Bunnenger	90 Box 1149 Saint, Albans, WV 25177	304-910-0348	chrz.bunnenger@cerberus-security.com
Nitro Construction Services	Matt Means	4300 1st Ave Nitro W.V. 25143	304-395-5665	mmeans@nitrocs.com
Adventure Technology	Jake Gump	950 Kanawha Blvd Charleston 25301	304-342-0796	jgump@advantage.tech
Johnson Controls	Eli Hensel	108 Craddock Way #7 Poca, WV	304-654-5314	eli.hensel@jci.com
Electronic Specialty Company	Travis Atkins	1325 Dunbar Ave Dunbar WV 26044	304-766-6277	Travis-Adkins@ElectronicSpecialty.com
Newtech Sys.	Shawn Schrader	420 16th Street Dunbar WV	304-766-0000	schrader@newtech-sys.com