

# SOLICITATION NUMBER: 2026-02 City Service Center Networking Equipment

## Addendum Number: 1

---

The purpose of this addendum is to modify the Expression of Interest Solicitation identified as **2026-02 City Service Center Networking Equipment** (“Solicitation”) to reflect the change(s) identified and described below.

### Applicable Addendum Category:

- ☐ Modify bid opening date and time
- ☐ Modify specifications of product or service being sought
- ☒ Attachment of vendor questions and responses
- ☐ Attachment of pre-bid sign-in sheet
- ☐ Correction of error
- ☐ Other :

**Description of Modification to Solicitation:** Addendum 1 is issued to attach vendor questions and responses received.

**Additional Documentation:** Documentation related to this Addendum (if any) has been included herewith and is specifically incorporated herein by reference.

### Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

SOLICITATION NUMBER: 2026-02 City Service Center Networking  
Equipment  
Addendum Number: 1

---

**Questions and Answers**

Q1: What is the output voltage(s)? (voltage of equipment being protected/ i.e. 120v, 208v, 240v)

A1: 120v

Q2: What is the desired battery backup runtime in minutes? (Standard is 15-20 minute)

A2: 15-20 minutes

Q3: What is the sites input voltage for the UPS should be since I want to make sure I'm getting the appropriate model.

A3: 120v



## ADDENDUM ACKNOWLEDGEMENT FORM

### SOLICITATION NO.: 2026-02 City Service Center Networking Equipment

**Instructions:** Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

**Acknowledgment:** I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received: (Check the box next to each addendum received)

- |   |  |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6  |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7  |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8  |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9  |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company Name:	
Authorized Signature:	
Printed Name:	
Date:	

**NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing**