

SOLICITATION: 2026-26 Haddad Floating Dock Decking Replacement

Addendum Number: 2

The purpose of this addendum is to modify the Expression of Interest Solicitation identified as **2026-26 Haddad Floating Dock Decking Replacement** (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other :

Description of Modification to Solicitation: Addendum 2 is issued to attach vendor questions and responses.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

SOLICITATION: 2026-26 Haddad Floating Dock Decking Replacement

Addendum Number: 2

Questions and Answers

Q1: How does the payment process work for the awarded contractor?

A1: As stated in the General Terms and Conditions, Section 15 – Payment in Arrears, the City pays in arrears only. Payment is made after the work has been performed and a proper invoice has been submitted and accepted; no advance payments are permitted.

Q2: To confirm, are all signs going to be reused?

A2: This project includes replacement of the nailer boards and decking boards only. Any signage attached to the existing decking surface shall be carefully removed and reinstalled on the new decking surface; new signage is not required.

Q3: Is the City providing the security fence at the three entry points to the doc area? Also, how tall does the fence need to be?

A3: No. Providing and maintaining security fencing at the three entry points will be the responsibility of the awarded contractor. A standard construction security fence, typically 6 to 8 feet in height, will be acceptable unless otherwise required by applicable codes or regulations.

Q4: To confirm, is the board under the rubber bumper staying?

A4: Yes. The rubber bumpers are attached to a composite board that is bolted to the steel deck frame, and that composite board is to remain in place. Only the decking boards and nailer boards are to be removed and replaced by the awarded contractor.



ADDENDUM ACKNOWLEDGEMENT FORM

SOLICITATION: 2026-26 Haddad Floating Dock Decking Replacement

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received: (Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company Name:	
Authorized Signature:	
Printed Name:	
Date:	

NOTE: This addendum acknowledgment should be submitted with the bid to expedite document processing