SOLICITATION NUMBER: 2026-43 Upper Theater Roof Replacement
Addendum Number: Two (2)

The purpose of this addendum is to modify the Expression of Interest Solicitation identified as **2026-43 Upper Theater Roof Replacement** ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

[☐] Modify bid opening date and time

[☐] Modify specifications of product or service being sought

[☐] Attachment of vendor questions and responses

[☐] Attachment of pre-bid sign-in sheet

[☐] Correction of error

[☒] Other: (Updated response to Q4 regarding garage load bearing information)

Description of Modification to Solicitation: Addendum 1 is issued to update the response to Q4 regarding the load bearing information.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.

2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

Vendor Questions and Responses

Q4: Will the City permit the contractor to utilize the adjacent parking garage roof for material staging, debris handling, and operation of a telehandler during the roof replacement project? If permitted, can the City provide the allowable load capacity of the parking garage roof and identify any restrictions or requirements associated with its use?

A4: For bid purposes, use of the parking garage roof for staging and equipment may be assumed – **provided uniform loading of the structure is less than 50 pounds per square foot**. The selected contractor will be responsible for providing an engineer's verification of the loading layout and use of the garage for review and approval by the City prior to proceeding.

ADDENDUM ACKNOWLEDGEMENT FORM

SOLICITATION: 2026-43 Upper Theater Roof Replacement

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received: (Check the box next to each addendum received)

[☐] Addendum No. 1

[☐] Addendum No. 2

[☐] Addendum No. 3

[☐] Addendum No. 4

[☐] Addendum No. 5

[☐] Addendum No. 6

[☐] Addendum No. 7

[☐] Addendum No. 8

[☐] Addendum No. 9

[☐] Addendum No. 10

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any City personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company Name:	
Authorized Signature:	
Printed Name:	
Date:	

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing